



6109 South Don Carlos Dr.  
Taylorsville, Utah 84118

801-403-8803 801-205-9554 Fax: 801-967-5326  
a1environmentalcameron@yahoo.com

## **Addendum**

**RE: Asarco lab South and North buildings.**

**The Black table tops do not contain asbestos and can be left in during demolition. A-1 Environmental sample results from Crisp Analytical can be reviewed in the sample results file. They are Non Detected. The black table tops are homogeneous to both buildings**

**Also the rooms are numbered in the south building on the doors or wall next to rooms for identification**

**Respectfully submitted,**

**Mathew Hernandez**  
**ASB #712 A-1 Environmental #392**